

**BIDS AND AWARDS COMMITTEE  
SUPPLEMENTAL BID BULLETIN NO. 01**

**Rebidding for Supply, Delivery, Testing and Commissioning  
of Brand New Fire Truck**

*Invitation to Bid No. 2023-01-037*

The PNOC Bids and Awards Committee hereby adopts the following provision in the Philippine Bidding Documents:

1. Amendments/Inclusions on **Section VII. Technical Specifications:**

Item No.	Reference	From	To
1	Page 29 <b>Water Tank (without content) - Equipment</b>	- Dismountable baffle plates	- <b>Fixed or dismountable baffle plates</b>
2	Page 29 <b>Foam Compound Tank (without content) - Equipment</b>	- Dismountable baffle plates	- <b>Fixed or dismountable baffle plates</b>
3	Page 35 <b>Water Tank (without content) - Equipment</b>	- Dismountable baffle plates	- <b>Fixed or dismountable baffle plates</b>
4	Page 35 <b>Foam Compound Tank (without content) - Equipment</b>	- Dismountable baffle plates	- <b>Fixed or dismountable baffle plates</b>

2. Clarification/s on **Section VII. Technical Specifications:**

Query	Clarification/Resolution
<p><b>1. Water Tank (without content)</b></p> <p>xxx</p> <p>Material: Made of glass fibre reinforced polyester (GRP), 10 to 14 mm thick</p> <p style="text-align: center;"><b>or</b></p> <p>- <b>Made of Polypropylene (PP), 15 mm (min)<sup>1</sup></b></p> <p>xxx</p>	<p><b>No revision</b></p>
<p><b>2. Foam Compound Tank (without content)</b></p> <p>xxx</p> <p>Material: Made of glass fibre reinforced polyester (GRP), 10 to 14 mm thick</p> <p style="text-align: center;"><b>or</b></p> <p>- <b>Made of Polypropylene (PP), 15 mm (min)</b></p> <p>- <b>10 years warranty for the foam tank<sup>2</sup></b></p>	<p><b>No revision</b></p>
<p><b>3. Water Pump</b></p> <p>xxx</p> <p>Type: <b>Two stage/Double Stage Centrifugal fire pump with normal pressure (3000LPM @10 bar) and high pressure (400LPM @40 bar)</b></p> <p>Material: <b>Castings (Impeller, pump cover, pump housing) are made from sea water resistant light aluminum alloy. Pump shaft, Split water rings are made from corrosion-resistant steel (Stainless Steel). Drain cock are made from brass material.</b></p>	

<sup>1</sup> Request for Consideration Letter of JROG Marketing dated February 01, 2023.

<sup>2</sup> Ibid.

<p>Sealing: <b>Radial/Mechanical Shaft Seal</b></p> <p>Priming Device: <b>Fully automatic priming system integrated with the fire pump, no foreign agents are necessary for the priming system</b></p> <ul style="list-style-type: none"> <li>- <b>The priming system shall be same brand with fire pump and/or fire truck manufacturer</b></li> <li>- <b>Bidder shall submit fire pump performance test and hydrostatic test report</b></li> </ul> <p>Manifolds: xxx</p> <ul style="list-style-type: none"> <li>- <b>Pump drainage Must submit the authenticated/notarized EN 1028 Certificate.</b></li> <li>- <b>Fire pump and foam proportioning system shall be same brand.<sup>3</sup></b></li> </ul>	<p><b>No revision</b></p>
<p>4. Under the Technical Specifications of PNOC, under manifolds, What is your minimum requirement for the Collecting Breeching since your specs is 4 male Inlets.<sup>4</sup></p>	<p><b>Collecting Breeching is 4 male inlets 2.5" NHT and female outlet 5" NHT thread. No changes on this item.</b></p>

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Document.

For guidance and information of all concerned.

Issued this 07 February 2023.

  
**ATTY. GRACIELA M. BARLETA**  
 Chairperson

<sup>3</sup> Ibid.

<sup>4</sup> Request for Clarifications of Royal Arc Med Solution Inc. dated February 02, 2023