

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BID BULLETIN NO. 02

Supply, Delivery, Installation, Testing and Commissioning of 150 kWp Solar PV Rooftop System at Angeles City Water District (ACWD) Central Reservoir Pumping Station Warehouse

Invitation to Bid No. 2024-08-108

The PNOC Bids and Awards Committee hereby adopts the following provision in the Philippine Bidding Documents:

1. Amendments/Inclusions

Item No.	FROM	TO																
1	Section VII. Technical Specifications p.29 xxx	Section VII. Technical Specifications p.29 xxx																
	<table border="1"> <thead> <tr> <th>Item No.</th> <th colspan="2">Technical Requirements</th> </tr> </thead> <tbody> <tr> <td rowspan="2">2</td> <td colspan="2">INVERTER</td> </tr> <tr> <td>Nominal Output Voltage</td> <td><u>Three-Phase, 220V to 240V</u></td> </tr> </tbody> </table>	Item No.	Technical Requirements		2	INVERTER		Nominal Output Voltage	<u>Three-Phase, 220V to 240V</u>	<table border="1"> <thead> <tr> <th>Item No.</th> <th colspan="2">Technical Requirements</th> </tr> </thead> <tbody> <tr> <td rowspan="2">2</td> <td colspan="2">INVERTER</td> </tr> <tr> <td>Nominal Output Voltage</td> <td><u>Three-Phase, 440V to 480V</u></td> </tr> </tbody> </table>	Item No.	Technical Requirements		2	INVERTER		Nominal Output Voltage	<u>Three-Phase, 440V to 480V</u>
	Item No.	Technical Requirements																
2	INVERTER																	
	Nominal Output Voltage	<u>Three-Phase, 220V to 240V</u>																
Item No.	Technical Requirements																	
2	INVERTER																	
	Nominal Output Voltage	<u>Three-Phase, 440V to 480V</u>																
xxx	xxx																	
2	<p>Paragraph 7 of the Instructions to Bidders p.8</p> <p>Bids must be duly received by the BAC Secretariat through manual submission at the address indicated below on or before September 03, 2024 (10:00 AM). Late bids shall not be accepted.</p>	<p>Paragraph 7 of the Instructions to Bidders p.8</p> <p>Bids must be duly received by the BAC Secretariat through manual submission at the address indicated below on or before September 10, 2024 (10:00 AM). Late bids shall not be accepted.</p>																

MAIN OFFICE

PNOC Building 6, Energy Center
Rizal Drive, Bonifacio Global City
Taguig, Philippines 1634
(+632) 8789 7662
www.pnoc.com.ph

INDUSTRIAL PARK

Barangay Batangas Dos, Mariveles
Bataan, Philippines 2105
(+6347) 244 5884 and 86
industrialpark@pnoc.com.ph

ENERGY SUPPLY BASE

Barangay Mainaga, Mabini
Batangas, Philippines 4202
+63 917 515 4036
energysupplybase@pnoc.com.ph

3	Paragraph 9 of the Instructions to Bidders p.8 Bid opening shall be on September 03, 2024 (10:30 AM) . . . x x x	Paragraph 9 of the Instructions to Bidders p.8 Bid opening shall be on September 10, 2024 (10:30 AM) . . . x x x
---	--	--

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

For guidance and information of all concerned.

Issued this 02 September 2024.

ATTY. JOSEPHINE CASSANDRA J. CUI
 Chairperson
 Bids and Awards Committee


