

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BID BULLETIN NO. 01

Supply, Delivery, Installation, Commissioning, Testing and Operational Demonstration of at least 80kW Electric Vehicle Charging Station (EVCS) – Fast / Rapid at Bataan Tourism Center, Balanga City Bataan

Invitation to Bid No. 2024-09-133

The PNOB Bids and Awards Committee hereby adopts the following amendments in the Philippine Bidding Documents:

1. Additional Specifications on Cabling:

- a) Length of Cable from PANELCO transformer to the Service Entrance up to the charger is 50 to 70 meters. The electrical cable must be compatible with and can support the electrical load requirement.
- b) The cabling to the charger must be underground

2. Additional Technical Document (to be included in the Technical Component Envelope):

- a) Certification from the manufacturer with respect to the compatibility of the EV Chargers with both CCS Combo 2 and GB/T standards.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Document.

For guidance and information of all concerned.

Issued this 1st day of September 2024.



for: **ATTY. JOSEPHINE CASSANDRA J. CUI**
Chairperson

