

**SPECIAL BIDS AND AWARDS COMMITTEE**
**SUPPLEMENTAL BID BULLETIN NO. 01**
**Construction of New Pier**  
**Invitation to Bid No. 2023-02-052**

The PNOC Special Bids and Awards Committee hereby adopts the following clarifications in the Philippine Bidding Documents:

Item no.	Queries	Response
1	Please confirm whether Bidder can submit a Bid Securing Declaration only for the bid security.	Yes, the Bidder can submit a Bid Securing Declaration only for the bid security.
2	Please provide the Defect Liability Period as the tender documents do not mention the Defect Liability Period.	The warranty against Structural Defects and Failures shall cover the following periods from final acceptance, except those occasioned by force majeure:  b) Permanent Structures: Fifteen (15) years
3	Please provide the Conditions of Contract for the project consistent with the tender documents.	Please refer to the General Conditions of the Contract and the Special Conditions of the Contract found in the published Philippine Bidding Documents. More details of the project are found in the published Terms of Reference/Bill of Quantities/Plans and Drawings of the project.
4	In Item No.2.1 12m Lamp Post – Single Arm Hot Dip Galvanized discrepancy in quantity was observed between the Plans & Drawings (72 sets) and Bill of Quantities (67 sets).	The quantity in the Bill of Quantities shall govern. <b>67 sets of 12m Lamp Post – Single Arm Hot Dip Galvanized.</b> But for the design and details the plans and drawings shall govern.
5	In Item No. 2.3 Supply and Install Complete, Lighting Pole Foundation discrepancy in quantity was observed between the Plans & Drawings (78 sets) and Bill of Quantities (73 sets).	The quantity in the Bill of Quantities shall govern. <b>73 sets of Supply and Install Complete, Lighting Pole Foundation.</b> But for the design and details the plans and drawings shall govern.

6	In Item No. 10 High Mast Ladder, discrepancy in unit used was observed between the Plans & Drawings (360 steps) and Bill of Quantities (6 sets).	The unit used in the Bill of Quantities shall govern. <b>6 sets of High Mast Ladder.</b> But for the design and details of the ladder, plans and drawings shall govern.
7	In Item No. 3.1 Roadway Luminaire 150W LED, 230 volts, discrepancy in quantity was observed between the Plans & Drawings (72 sets) and Bill of Quantities (67 sets).	The quantity in the Bill of Quantities shall govern. <b>67 sets of Roadway Luminaire 150W LED, 230 Volts.</b> But for the design and details, plans and drawings shall govern.
8	Please confirm if dimensions for High Mast Pole Left Elevation was inquired whether it really is 191mm & 30mm as highlighted.	Yes, the distance from base plate to the first step of the ladder is <b>191mm</b> and the distance between steps is <b>30mm.</b>

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Document.

For guidance and information of all concerned.

Issued this 11 May 2023.

  
**ATTY. RONALD C. CHUA**  
 Chairperson

